

FIRE SAFETY CERTIFICATE

No. 400/ASD/PMG

Dated: 23 Jul 2025

Certified that the **APS Dinjan Building** at **Dinjan Military Station** comprised of **0** basement(s) and **1st Floor & Ground Floor** owned/ occupied by **Army Public School Dinjan** have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on **13 Dec 2024** (date of inspection) in the presence of **Principal, Army Public School** and that the building/premises is fit for occupancy upto classes XII With effect from **13 Dec 2024** for a period of **01 year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. **Fire Extinguishers & Equipment** :-

- Adequate number of ISI-marked fire extinguishers placed at strategic points.
- Fire buckets, sand buckets, fire balls and other fire-fighting tools as required are available.

2. **Emergency Exit Plan** :-

- Clearly marked, unobstructed emergency exit routes on each floor.
- Display of fire evacuation plans in corridors and classrooms.

3. **Fire Drill & Training** :- Regular fire drills and training sessions are conducted for staff and students.

Issued on **24 July 2025** at **Dinjan Military Station** by

Signature with Seal : 

Name : Colonel Amool Sudhan

Designation : OIC, School

Name & Address of Department/Office: 2 Mtn DOU

C/o 99 APO



To

The Principal
Army Public School Dinjan

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to Not applicable for Army Public School Dinjan as it is run by AWES under the aegis of HQ 2 Mtn Div


Colonel Amool Sudhan
OIC, School

(Name and designation of the authorized signatory)

